


**2012 ANNUAL DRINKING WATER QUALITY REPORT**
**PWSID #: 6200051 NAME: Titusville Municipal Water Works**

*Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda.* (This report contains important information about your drinking water. Have someone translate it for you, or speak with someone who understands it.)

**WATER SYSTEM INFORMATION:**

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Titusville Water Works at 814-827-5300 X 311

We want you to be informed about your water supply.

**SOURCE(S) OF WATER:**

Our water source(s) is/are:

10 interconnected Wells located at the Titusville Water Works property / 220 Oil Creek Drive

Titusville PA 16354

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the *Safe Drinking Water Hotline* (800-426-4791).

**MONITORING YOUR WATER:**

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2012. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

**DEFINITIONS:**

*Action Level (AL)* - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.



**Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Minimum Residual Disinfectant Level (MinRDL)** - The minimum level of residual disinfectant required at the entry point to the distribution system.

**Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water.

**Mrem/year** = millirems per year (a measure of radiation absorbed by the body)

**ppm** = parts per million, or milligrams per liter (mg/L)

**pCi/L** = picocuries per liter (a measure of radioactivity)

**ppq** = parts per quadrillion, or picograms per liter

**ppb** = parts per billion, or micrograms per liter (µg/L)

**ppt** = parts per trillion, or nanograms per liter

**DETECTED SAMPLE RESULTS:**

<b>Chemical Contaminants</b>								
<b>Contaminant</b>	<b>MCL in CCR Units</b>	<b>MCLG</b>	<b>Level Detected</b>	<b>Range of Detections</b>	<b>Units</b>	<b>Sample Date</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
Chlorine	MRDL-4	MRDLG-4	0.545	0.34-0.545	MG/L	2012	N	Water additive used to control microbes
Nitrate	10	10	0.57	0-0.57	MG/L	6/19/2012	N	Runoff from fertilizer
Di(2ethylhexyl) phthalate	0.006	0	0.0034	0-0.0034	MG/L	Sample not taken	Y**	Discharge from rubber and chemical factories
Barium (IOC)	2	2	0.054	0-0.054	MG/L	2011	N	Discharge of drilling wastes, metal refineries, natural deposits
Chlorodibromomethane (THM)	80	N/A	0.00103	0-0.00103	MG/L	2012	N	Byproduct of drinking water chlorination
Nitrite	1	1	0.003	0-0.003	MG/L	2012	N	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion from natural deposits

\*EPA's MCL for fluoride is 4 ppm. However, Pennsylvania has set a lower MCL to better protect human health.

\*\*Please see attached Public Notification sheet regarding failure to monitor SOC's in the second quarter.



**Entry Point Disinfectant Residual**

Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Chlorine	0.40	0.41	0.4-0.68	MG/L	5/8/2012	N	Water additive used to control microbes.

**Lead and Copper**

Contaminant	Action Level (AL)	MCLG	90 <sup>th</sup> Percentile Value	Units	# of Sites Above AL of Total Sites	Violation Y/N	Sources of Contamination
Lead	15	0	1.8	ppb	1	N	Corrosion of household plumbing.
Copper	1.3	1.3	0.123	ppm	0	N	Corrosion of household plumbing.

**Microbial**

Contaminants	MCL	MCLG	Highest # or % of Positive Samples	Violation Y/N	Sources of Contamination
Total Coliform Bacteria	<p>For systems that collect &lt;40 samples/month:</p> <ul style="list-style-type: none"> <li>• More than 1 positive monthly sample</li> </ul> <p>For systems that collect ≥ 40 samples/month:</p> <ul style="list-style-type: none"> <li>• 5% of monthly samples are positive</li> </ul>	0	1	N	Naturally present in the environment.



## ***EDUCATIONAL INFORMATION:***

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* (800-426-4791).

### ***Information about Lead***

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Titusville Water Works is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components.

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.





## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

ESTE INFORME CONTIENE UNFORMACION MUY IMPORTANTE SOBRE SU AGUA DE BEBER. TRADUZCALO O HABLE CON ALGUIEN QUE LO ENTIENDA BIEN.

Monitoring Requirements Not Met for Titusville City WTP

Our water system violated a drinking water standard over the past year. Even though this was not an emergency, as our customers, you have a right to know what happened and what we did to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the monitoring period of 2012 we did not sample for the SOC Di(2-ethylhexyl) phthalate and therefore we cannot be sure of the quality of our drinking water during that time.

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for these contaminants and how many samples we are supposed to take, how many samples we took, when samples should have been taken and the date on which follow-up samples were or will be taken.

Contaminant	Required Sampling Frequency	Number of Samples Required	When Samples Should Have Been Taken	When Samples Were or Will Be Taken
Di(2-ethylhexyl) phthalate	Annual	1 per entry point	2012 during quarter with highest previous result	Next monitoring period for those contaminants

Corrective Action Taken: SUBMIT SAMPLE IN SECOND QUARTER 2013

For more information, please contact RANDALL J. NEBEL at 814.827.5300 x 311  
PWS Contact Person Phone Number

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Titusville Municipal Water.

PWS ID No.: 6200051

Date distributed: APRIL 1, 2013

Violation ID 2013-11836





Microbac Laboratories, Inc.  
Erie Division

1982 Wager Road • Erie, PA 16509 • Phone: 814-825-8533 • Fax: 814-825-9254  
Larry Lewis, Managing Director • E-mail: erie@microbac.com • http://www.microbac.com

**CERTIFICATE OF ANALYSIS**

Work Order Number:  
13D1164

Titusville, City Of, Water Plant  
Attn: Sines  
107 N. Franklin St.  
Titusville, PA 16354

Date Reported 04/15/2013  
Date Received 04/02/2013  
Account Number 00000003206



Purchase Order:

Subject: 2013 Annual DEP SOC (2nd Q)

SMP	TEST	METHOD	RESULT	UNITS	ANALYSIS			
					DATE	TIME	TECH	
01	Entry Point 101 Sample Type: E Sample Point: 101 Sample Time: 04/02/2013 @ 9:15							
	Farm filed with DEP Semi-volatile Organics	EPA 825.2						
	Bis(2-ethylhexyl) phthalate		<1.2	ug/L	04/09/13	23:10	JMS	

**Order Notes**

The SOC analyses were sub-contracted to Microbac Laboratories, Inc./Central Pennsylvania Division, NELAP PA ID# 22-00578, NELAC NY ID#11650 (W.O. 1312478 )

All samples received in proper condition and results conform to ISO 17025 unless otherwise noted

Some or all of the samples were collected by the customer. The verifiability of the final results are therefore limited by the customer's reported values. Microbac Laboratories, Inc. assumes that all sampling instructions are followed, and the data upon which these final results are based, have been accurately supplied by the client.

**Notes and Definitions**

- SI Surrogate recovery was above laboratory acceptance limits. No negative impact on the data.
- RPD Sample Duplicate Relative Percent Difference (RPD) was out of acceptance limits.
- LCS+ The LCS recovery was above the laboratory acceptance limits. The reported result was less than the reporting limit.
- A-01 LCS @ lower conc. acceptable (BS2), batch data accepted based on BS2

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.  
USDA-EPA-NIOSH Testing Food Sanitation Consulting Chemical and Microbiological Analyses and Research

NELAP accredited by PA, NY. Visit our website to view our current NELAC accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes

AMA accredited for Environmental Lead. Visit our website to view our current AMA LAP, LLC accreditation.





**cityservices@cityoftitusvillepa.gov**

---

**From:** Randy Nebel(City of Titusville) [depdir@cityoftitusvillepa.gov]  
**Sent:** Thursday, June 13, 2013 11:24 AM  
**To:** adminservices@cityoftitusvillepa.gov  
**Cc:** dpwclk@cityoftitusvillepa.gov; cityservices@cityoftitusvillepa.gov; manager@cityoftitusvillepa.gov  
**Subject:** RE: Final 2012 CCR

GREAT !!

---

**From:** adminservices@cityoftitusvillepa.gov [mailto:adminservices@cityoftitusvillepa.gov]  
**Sent:** Thursday, June 13, 2013 11:20 AM  
**To:** 'Randy Nebel(City of Titusville)'  
**Cc:** dpwclk@cityoftitusvillepa.gov; cityservices@cityoftitusvillepa.gov; manager@cityoftitusvillepa.gov  
**Subject:** RE: Final 2012 CCR  
**Importance:** High

Randy,

The posting of the 2012 CCR link <http://www.cityoftitusvillepa.gov/files/2012%20CCR.pdf> to the City's website is complete. I verified the link is accessible on the EPAs website as well.

A note will be added to the July City Services bills to be mailed June 28<sup>th</sup> with directions on how to access the link. There will also be a box added to the return portion of the city services bills giving customers the option to elect a paper copy of the report.

Since the report is 6 pages it would not be cost effective to mail with July bills.

Lisa,

Will you be doing the copies for the apartments again?

Diana Durstine  
 Finance Director/Assistant to the City Manager  
 City of Titusville, Pennsylvania  
 107 N Franklin St  
 Titusville, PA 16354

Phone: 814-827-5300 ext 303  
 Fax: 814-827-9458

[www.cityoftitusvillepa.gov](http://www.cityoftitusvillepa.gov)



Please consider the environment and costs when printing this email.

*This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the system manager. Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of the City of Titusville. Finally, the recipient should check this email and any attachments for the presence of viruses. The City of Titusville accepts no liability for any damage caused by any virus transmitted by this email.*

*"In accordance with Federal law and U.S. Department of Agriculture policy, this institution is prohibited from discriminating on the basis of race, color, national origin, age, disability, sex, familiar status sexual orientation, and reprisal. (Not all prohibited bases apply to all programs).*

*To file a complaint of discrimination, write to: USDA, Assistant Secretary for Civil Rights, Office of the Assistance Secretary for Civil Rights, 1400 Independence Avenue, S.W. Stop 9410, Washington, D.C. 20250-9410, or call Toll-free at (866) 632-9992 or (800) 877-8339 (TDD) or (866) 377-8642 (English Federal-relay) or (800) 845-6136 (Spanish Federal Relay). USDA is an equal opportunity provider and employer."*

-----Original Message-----

**From:** Randy Nebel(City of Titusville) [mailto:depdir@cityoftitusvillepa.gov]  
**Sent:** Thursday, June 13, 2013 10:24 AM  
**To:** [manager@cityoftitusvillepa.gov](mailto:manager@cityoftitusvillepa.gov); [adminservices@cityoftitusvillepa.gov](mailto:adminservices@cityoftitusvillepa.gov)  
**Cc:** [dpwclk@cityoftitusvillepa.gov](mailto:dpwclk@cityoftitusvillepa.gov)

6/13/2013



**Subject:** Final 2012 CCR

Larry..... FYI

Diana,

Attached find the 2012 Consumer Confidence Report required by law to be posted/distributed no later than July 1, 2013

Per our previous conversation and forwarded instructions for posting to the City website, please establish this prior to the above date.

DEP has requested we notify them upon appearance/posting.

We will supply a hard copy and the certification to DEP immediately after posting is complete and hard copies are delivered per DEP instructions.

Thanks,  
Randy

6/13/2013

